



1
A-1
PERSPECTIVE VIEW
SCALE : N T S

TABLE OF CONTENTS

REPUBLIC OF THE PHILIPPINES
OFFICE OF THE CITY/MUNICIPAL
ENGINEER/BUILDING OFFICIAL

DISTRICT/CITY/MUNICIPALITY

ARCHITECTURAL

- A-1 PERSPECTIVE VIEW & TABLE OF CONTENTS
- A-2 GROUND FLOOR PLAN SECOND FLOOR PLAN
- A-3 THIRD FLOOR & ROOF PLAN
- A-4 FRONT, RIGHT, REAR & LEFT ELEVATION
- A-5 LOGITUDINAL & CROSS SECTION, REFLECTED CEILING
- A-6 SCHED. OF DOORS & WINDOWS RAMP DETAILS, EAVES DETAIL, SUNBREAKER DETAIL DAMP PROOFING DETAIL, BALCONY RAILING DET.
- A-7 STAIR & HANDRAIL DETAIL
- A-8 TOILETS DETAIL

LAND USE & ZONING

LINE & GRADE

ARCHITECTURAL

STRUCTURAL

- S-1 FOUNDATION, 2ND&3RD FLR FRAMING PLAN SCHEDULE AND ELEVATION OF COLUMN
- S-2 ROOF FRAMING,SCHED OF SLAB&FOOTING DET OF TIE BEAM,STAIR ON GRADE&RAMP
- S-3 GROUND & SECOND FLOOR LIGHTING LAYOUT
- E-4 THIRD FLOOR LIGHTING & POWER LAYOUT

STRUCTURAL

SANITARY

ELECTRICAL

- E-1 GENERAL NOTES, SINGLE LINE DIAGRAM, LOAD SCHEDULE, LEGEND, RISER DIAGRAM
- E-2 GROUND & SECOND FLOOR POWER LAYOUT
- E-3 SCHEDULE OF BEAMS/GIRDERS DETAIL OF STAIR
- S-4 TRUSS DIAGRAM DETAILS OF STEEL CONNECTION

ELECTRICAL

SANITARY

- P-1 ROOF DRAIN LAYOUT , PLUMBING RO-IN LAYOUT
- P-2 ISOMETRIC VIEW
- P-3 SEPTIC TANK, CATCH BASIN & COVER DETAIL, LEGEND, NOTES & DESIGN CRITERIA

MECHANICAL



SCHEDULE OF FINISH

FLOORS :

- FL1 - PLAIN CEMENT FLOOR FINISH
- FL2 - PLAIN CEMENT FLOOR ROUGH WITH GROOVES
- FL3 - 200X200 VITRIFIED FLR TILES (UNGLAZED)
- FL4 - 300X300 VINYL TILES
- FL5 - PLAIN CEMENT FLOOR FINISH WITH WATER PROOFING



WALLS :

- WF1 - 150 MM THK. CHB W/ PLAIN CEMENT PLASTER FIN (PAINTED)
- WF2 - 150 MM THK. CHB W/ PLAIN CEMENT PLASTER FIN (PAINTED) PROVIDE GROOVES
- WF3 - 200X200 VITRIFIED WALL TILES (GLAZED)
- WF4 - 100 MM THK. CHB W/ PLAIN CEMENT PLASTER FIN (PAINTED)
- WF5 - 50 MM SQ. CYCLONE WIRE ON 75mmø G.I. PIPE VERT @1200mm O.C. & 50mmø G.I. PIPE HOR. @600mm O.C.



<p>REPUBLIC OF THE PHILIPPINES DEPARTMENT OF EDUCATION (DepED) TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING MERALCO AVENUE, PASIG CITY</p>	CONSULTANT / DESIGNER	REVIEWED BY:	RECOMMENDING APPROVAL :	APPROVED FOR ACCREDITATION :	CONCURRED :	PROJECT TITLE :	PROJECT NO: 01-002	OWNER :	SHEET NO:
	 ALBERT Z. DE BELEN	 RAMON C. BACANI	 GILBERT S. REYES	 RAMON C. BACANI	 RAMON C. BACANI	THREE STOREY SIX CLASSROOM W/MULTI-PURPOSE	DESIGNED BY: AZB	DEPARTMENT OF EDUCATION DepED	A-2
	ARCHITECT IV PRC NO. : 0010990 PTR NO. : TIN : 149 460 161 DATE : 27 OCT. 2002	CHIEF ARCHITECTURAL DIVISION BUREAU OF DESIGN, DPWH	OIC, DIRECTOR III BUREAU OF DESIGN, DPWH	OIC, DIRECTOR IV BUREAU OF DESIGN, DPWH	UNDERSECRETARY DEPARTMENT OF EDUCATION (DepED)	LOCATION :	ENCODED BY: Max C	SHEET CONTENTS :	8
							CHECKED BY:	GROUND & SECOND FLOOR PLAN	
							DATE : 01 03		


NOTE: THIS DRAWING, AS AN INSTRUMENT OF SERVICE IS THE PROPERTY OF TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING AND AS SUCH MUST NOT BE REPRODUCED OR COPIED IN PART OR IN WHOLE WITHOUT THEIR PERMISSION. ALL DRAWINGS ARE TO BE RETURNED WHEN NO LONGER IN USE.




<p>REPUBLIC OF THE PHILIPPINES DEPARTMENT OF EDUCATION (DepED) TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING MERALCO AVENUE, PASIG CITY</p>	<p>CONSULTANT / DESIGNER ALBERT Z. DE BELEN ARCHITECT IV PRC NO. : 0010990 TIN : 149 460 161 PTR NO. : DATE : 27 OCT. 2002</p>	<p>REVIEWED BY: EMANUEL M. MONTAPAY CHIEF / ARCHITECTURAL DIVISION BUREAU OF DESIGN, DPWH</p>	<p>RECOMMENDING APPROVAL : SOFIA T. SANTIAGO OIC, DIRECTOR III BUREAU OF DESIGN, DPWH</p>	<p>APPROVED FOR ACCREDITATION : GILBERTO S. REYES OIC, DIRECTOR IV BUREAU OF DESIGN, DPWH</p>	<p>CONCURRED : RAMON C. BACANI UNDERSECRETARY DEPARTMENT OF EDUCATION (DepED)</p>	<p>PROJECT TITLE : THREE STOREY SIX CLASSROOM W/MULTI-PURPOSE LOCATION :</p>	<p>PROJECT NO: 01-002 DESIGNED BY: AZB ENCODED BY: Max C CHECKED BY: DATE : 01 03</p>	<p>OWNER : DEPARTMENT OF EDUCATION DepED SHEET CONTENTS : THIRD FLOOR PLAN REFLECTED CEILING PLAN</p>	<p>SHEET NO: A-3 8</p>
---	---	--	--	--	--	---	---	---	---------------------------------------

NOTE: THIS DRAWING, AS AN INSTRUMENT OF SERVICE IS THE PROPERTY OF TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING AND AS SUCH MUST NOT BE REPRODUCED OR COPIED IN PART OR IN WHOLE WITHOUT THEIR PERMISSION. ALL DRAWINGS ARE TO BE RETURNED WHEN NO LONGER IN USE.
REP. ACT 545






1 LONGITUDINAL SECTION
A-5 SCALE : 1 : 100 METERS












2 CROSS SECTION
A-5 SCALE : 1 : 100 METERS



3 ROOF PLAN
A-5 SCALE : 1 : 100 METERS

<p>REPUBLIC OF THE PHILIPPINES DEPARTMENT OF EDUCATION (DepED) TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING MERALCO AVENUE, PASIG CITY</p>	<p>CONSULTANT / DESIGNER ALBERT Z. DE BELEN ARCHITECT IV PRC NO. : 0010990 TIN : 149 460 161 PTR NO. : DATE : 27 OCT. 2002</p>	<p>REVIEWED BY: EMMANUEL M. MONTAPAY CHIEF / ARCHITECTURAL DIVISION BUREAU OF DESIGN, DPWH</p>	<p>RECOMMENDING APPROVAL : SOFIA T. SANTIAGO OIC, DIRECTOR III BUREAU OF DESIGN, DPWH</p>	<p>APPROVED FOR ACCREDITATION : GILBERTO S. REYES OIC, DIRECTOR IV BUREAU OF DESIGN, DPWH</p>	<p>CONCURRED : RAMON C. BACANI UNDERSECRETARY DEPARTMENT OF EDUCATION (DepED)</p>	<p>PROJECT TITLE : THREE STOREY SIX CLASSROOM W/MULTI-PURPOSE LOCATION :</p>	<p>PROJECT NO: 01-002 DESIGNED BY: AZB ENCODED BY: Max C CHECKED BY: DATE : 01 03</p>	<p>OWNER : DEPARTMENT OF EDUCATION DepED SHEET CONTENTS : LONGITUDINAL, CROSS SECTION & ROOF PLAN DAMP PROOFING DETAIL, BALCONY RAILING DET.</p>	<p>SHEET NO: A-5 8</p>
---	---	---	--	--	--	---	---	---	---------------------------------------









NOTE: THIS DRAWING, AS AN INSTRUMENT OF SERVICE IS THE PROPERTY OF TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING AND AS SUCH MUST NOT BE REPRODUCED OR COPIED IN PART OR IN WHOLE WITHOUT THEIR PERMISSION. ALL DRAWINGS ARE TO BE RETURNED WHEN NO LONGER IN USE.
REP. ACT 545



<p>REPUBLIC OF THE PHILIPPINES DEPARTMENT OF EDUCATION (DepED) TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING MERALCO AVENUE, PASIG CITY</p>	<p>CONSULTANT / DESIGNER ALBERT Z. DE BELEN ARCHITECT IV PRC NO. : 0010990 TIN : 149 460 161 PTR NO. : DATE : 27 OCT. 2002</p>	<p>REVIEWED BY: EMMANUEL M. SANTAPAY CHIEF / ARCHITECTURAL DIVISION BUREAU OF DESIGN, DPWH</p>	<p>RECOMMENDING APPROVAL : SOFIAT. SANTIAGO OIC, DIRECTOR III BUREAU OF DESIGN, DPWH</p>	<p>APPROVED FOR ACCREDITATION : GILBERTO S. REYES OIC, DIRECTOR IV BUREAU OF DESIGN, DPWH</p>	<p>CONCURRED : RAMON C. BACANI UNDERSECRETARY DEPARTMENT OF EDUCATION (DepED)</p>	<p>PROJECT TITLE : THREE STOREY SIX CLASSROOM W/MULTI-PURPOSE LOCATION :</p>	<p>PROJECT NO: 01-002 DESIGNED BY: AZB ENCODED BY: Max C CHECKED BY: DATE : 01 03</p>	<p>OWNER : DEPARTMENT OF EDUCATION DepED SHEET CONTENTS : SCHED. OF DOORS & WINDOWS RAMP DETAILS, EAVES DETAIL, SUNBREAKER DETAIL DAMP PROOFING DETAIL, BALCONY RAILING DET.</p>	<p>SHEET NO: A-6 8</p>
---	---	---	---	--	--	---	---	---	--


NOTE: THIS DRAWING, AS AN INSTRUMENT OF SERVICE IS THE PROPERTY OF TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING AND AS SUCH MUST NOT BE REPRODUCED OR COPIED IN PART OR IN WHOLE WITHOUT THEIR PERMISSION. ALL DRAWINGS ARE TO BE RETURNED WHEN NO LONGER IN USE.

REP. ACT 545




<p>REPUBLIC OF THE PHILIPPINES DEPARTMENT OF EDUCATION (DepED) TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING MERALCO AVENUE, PASIG CITY</p>	<p>CONSULTANT / DESIGNER ALBERT Z. DE BELEN ARCHITECT IV PRC NO. : 0010990 TIN : 149 460 161 PTR NO. : DATE : 27 OCT. 2002</p>	<p>REVIEWED BY: EMMANUEL M. MONTAPAY CHIEF / ARCHITECTURAL DIVISION BUREAU OF DESIGN, DPWH</p>	<p>RECOMMENDING APPROVAL : SOFIA T. SANTIAGO OIC, DIRECTOR III BUREAU OF DESIGN, DPWH</p>	<p>APPROVED FOR ACCREDITATION : GILBERTO S. REYES OIC, DIRECTOR IV BUREAU OF DESIGN, DPWH</p>	<p>CONCURRED : RAMON C. BACANI UNDERSECRETARY DEPARTMENT OF EDUCATION (DepED)</p>	<p>PROJECT TITLE : THREE STOREY SIX CLASSROOM W/MULTI-PURPOSE LOCATION :</p>	<p>PROJECT NO: 01-002 DESIGNED BY: AZB ENCODED BY: Max C CHECKED BY: DATE : 01 03</p>	<p>OWNER : DEPARTMENT OF EDUCATION DepED SHEET CONTENTS : TOILETS DETAIL</p>	<p>SHEET NO: A-8 8</p>
---	---	---	--	--	--	--	---	--	--------------------------------


NOTE: THIS DRAWING, AS AN INSTRUMENT OF SERVICE IS THE PROPERTY OF TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING AND AS SUCH MUST NOT BE REPRODUCED OR COPIED IN PART OR IN WHOLE WITHOUT THEIR PERMISSION. ALL DRAWINGS ARE TO BE RETURNED WHEN NO LONGER IN USE.
REP. ACT 545









A
S-1 FOUNDATION PLAN
SCALE : 1:100 M.










B
S-1 2ND & 3RD FLOOR FRAMING PLAN
SCALE : 1:100 M.




C
S-1 ELEVATION OF COLUMN
SCALE : 1 : 25 M


COLUMN SCHEDULE			
LEVEL	C-1	C-2	C-3
2ND FLOOR LEVEL TO 3RD FLOOR LEVEL	 <p>MAIN BAR: 6-#16mm TIES : #10 mm 1#50, 8#75, REST @ 150mm TO CENTER</p>	 <p>MAIN BAR: 12-#20mm TIES : #10 mm 1#50, 8#75, REST @ 150mm TO CENTER</p>	 <p>MAIN BAR: 12-#20mm TIES : #10 mm 1#50, 8#75, REST @ 150mm TO CENTER</p>
FOUNDATION LEVEL TO 2ND FLOOR LEVEL	 <p>MAIN BAR: 8-#16mm TIES : #10 mm 1#50, 8#75, REST @ 150mm TO CENTER</p>	 <p>MAIN BAR: 14-#20mm TIES : #10 mm 1#50, 10#75, REST @ 150mm TO CENTER</p>	 <p>MAIN BAR: 12-#20mm TIES : #10 mm 1#50, 10#75, REST @ 150mm TO CENTER</p>

<div><div>REPUBLIC OF THE PHILIPPINES DEPARTMENT OF EDUCATION (DepED) TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING MERALCO AVENUE, PASIG CITY</div></div>	CONSULTANT / DESIGNER	REVIEWED BY:	RECOMMENDING APPROVAL :	APPROVED FOR ACCREDITATION :	CONCURRED :	PROJECT TITLE :	PROJECT NO: 01-002	OWNER :	SHEET NO:	
	<div><div>BERNADETTE N. AQUINO</div><div>ENGINEER III</div><div>PRC NO. : 0074495 TIN : 199-674-196</div><div>PTR NO. : DATE :</div></div>	<div><div>WILFREDO S. LOPEZ</div><div>OIC, STRUCTURAL DIVISION</div><div>BUREAU OF DESIGN, DPWH</div></div>	<div><div>SOFIA T. SANTIAGO</div><div>OIC, DIRECTOR III</div><div>BUREAU OF DESIGN, DPWH</div></div>	<div><div>GILBERTO S. REYES</div><div>OIC, DIRECTOR IV</div><div>BUREAU OF DESIGN, DPWH</div></div>	<div><div>RAMON C. BACANI</div><div>UNDERSECRETARY</div><div>DEPARTMENT OF EDUCATION (DepED)</div></div>	THREE STOREY SIX CLASSROOM W/MULTI-PURPOSE	DESIGNED BY: BNA ENCODED BY: BNA CHECKED BY:	DEPARTMENT OF EDUCATION DepED	FOUNDATION, 2ND&3RD FLR FRAMING PLAN SCHEDULE AND ELEVATION OF COLUMN	S-1 4
						LOCATION :	DATE : 01 03	SHEET CONTENTS :		

NOTE: THIS DRAWING, AS AN INSTRUMENT OF SERVICE IS THE PROPERTY OF TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING AND AS SUCH MUST NOT BE REPRODUCED OR COPIED IN PART OR IN WHOLE WITHOUT THEIR PERMISSION. ALL DRAWINGS ARE TO BE RETURNED WHEN NO LONGER IN USE.




A
S-2 ROOF DECK FRAMING PLAN
SCALE : 1:100 M.




B
S-2 TYPICAL SLAB ELEVATION


SCHEDULE OF SLABS																	
FLOOR LEVEL	SLAB MARK	THICK-NESS in mm	REBAR SPACING in ALONG SHORT DIRECTION						REBAR SPACING in ALONG LONG DIRECTION						REMARKS		
			REBAR SIZE	LEFT SUPPORT		MIDSPAN		RIGHT SUPPORT		REBAR SIZE	LEFT SUPPORT		MIDSPAN			RIGHT SUPPORT	
				TOP	BOTT.	TOP	BOTT.	TOP	BOTT.		TOP	BOTT.	TOP	BOTT.		TOP	BOTT.
SECOND LEVEL																	
	S-1	100	10ø	200	300	-	300	200	300	10ø	250	300	-	300	250	300	TWO-WAY
	S-2	100	10ø	300	300	-	300	300	300	10ø	300	300	-	300	300	300	TWO-WAY





C
S-2 DETAIL OF TIE BEAM
SCALE NTS



D
S-2 DETAIL OF STAIR ON GRADE
SCALE 1 : 25M



E
S-2 DETAIL OF RAMP
SCALE 1 : 50M




F
S-2 TYP. FOOTING DETAIL
SCALE NTS

SCHEDULE OF FOOTING							
FOOTING MARK	FOOTING DIMENSIONS (mm)				REINFORCEMENT		REMARKS
	LENGTH (L)	WIDTH (W)	DEPTH (D)	Thickness (t)	BAR X	BAR Y	
F-1	1500	1500	1500	250	8 - 16mmø	8 - 16mmø	SQUARE FOOTING
F-2	2600	2600	1500	350	11 - 20mmø	11 - 20mmø	SQUARE FOOTING
F-3	2400	2400	1500	300	11 - 20mmø	11 - 20mmø	SQUARE FOOTING

 REPUBLIC OF THE PHILIPPINES DEPARTMENT OF EDUCATION (DepEd) TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING MERALCO AVENUE, PASIG CITY	CONSULTANT / DESIGNER BERNADETTE N. AQUINO ENGINEER III PRC NO. : 0074495 TIN : 199-674-196 PTR NO. : DATE :	REVIEWED BY: WILFREDO S. LOPEZ OIC, STRUCTURAL DIVISION BUREAU OF DESIGN, DPWH	RECOMMENDING APPROVAL : SOFA T. SANTIAGO OIC, DIRECTOR III BUREAU OF DESIGN, DPWH	APPROVED FOR ACCREDITATION : GILBERTO S. REYES OIC, DIRECTOR IV BUREAU OF DESIGN, DPWH	CONCURRED : RAMON C. BACANI UNDERSECRETARY DEPARTMENT OF EDUCATION (DepEd)	PROJECT TITLE : THREE STOREY SIX CLASSROOM W/MULTI-PURPOSE LOCATION :	PROJECT NO: 01-002 DESIGNED BY: BNA ENCODED BY: BNA CHECKED BY: DATE : 01 03	OWNER : DEPARTMENT OF EDUCATION DepEd SHEET CONTENTS : ROOF FRAMING, SCHED OF SLAB & FOOTING DET OF TIE BEAM, STAIR ON GRADE & RAMP	SHEET NO: S-2 4
---	---	--	---	--	--	---	--	--	-------------------------------------


NOTE: THIS DRAWING, AS AN INSTRUMENT OF SERVICE IS THE PROPERTY OF TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING AND AS SUCH MUST NOT BE REPRODUCED OR COPIED IN PART OR IN WHOLE WITHOUT THEIR PERMISSION. ALL DRAWINGS ARE TO BE RETURNED WHEN NO LONGER IN USE.

REP. ACT 545




A
S-3 TYPICAL BEAM ELEVATION


B E A M S C H E D U L E											
FLOOR LEVEL	BEAM MARK	BEAM DIMENSIONS (in / mm)		S T E E L R E I N F O R C E M E N T S						S T I R R U P S #10mm (UNLESS NOTED OTHERWISE)	
				REBAR (mm Ø)	LEFT		MID SPAN		RIGHT		
		b	h		TOP	BOTTOM	TOP	BOTTOM	TOP		BOTTOM
2ND FLOOR LEVEL	G-1	200	400	#20mm	3	2	2	2	3	2	1#50, 6#100, REST#200
	G-2	200	400	#20mm	4	3	2	2	4	3	1#50, 6#100, REST#200
	G-3	200	400	#20mm	3	3	2	2	3	3	1#50, 6#100, REST#200
	G-4	200	400	#20mm	3	2	2	2	6	4	1#50, 6#100, REST#200
	G-5	250	500	#20mm	6	4	2	4	6	4	1#50, 8#100, REST#200
	G-6	200	400	#20mm	4	3	2	2	6	4	1#50, 6#100, REST#200
	G-7	250	500	#20mm	6	4	2	6	6	4	1#50, 8#100, REST#200
	B-1	200	400	#16mm	4	2	2	2	4	2	1#50, 6#100, REST#200
	B-2	200	400	#16mm	2	2	2	4	2	2	1#50, 6#100, REST#200
	CB-1	200	400	#16mm	4	2	4	2	4	2	1#50, 6#100, REST#200
3RD FLOOR LEVEL											
	G-1	200	400	#20mm	2	2	2	2	2	2	1#50, 6#100, REST#200
	G-2	200	400	#20mm	3	2	2	2	3	2	1#50, 6#100, REST#200
	G-3	200	400	#20mm	3	2	2	2	3	2	1#50, 6#100, REST#200
	G-4	200	400	#20mm	3	2	2	2	5	3	1#50, 6#100, REST#200
	G-5	250	500	#20mm	5	3	2	4	5	3	1#50, 8#100, REST#200
	G-6	200	400	#20mm	3	2	2	2	6	4	1#50, 6#100, REST#200
	G-7	250	500	#20mm	6	4	2	6	6	4	1#50, 8#100, REST#200
	B-1	200	400	#16mm	4	2	2	2	4	2	1#50, 6#100, REST#200
	B-2	200	400	#16mm	2	2	2	3	2	2	1#50, 6#100, REST#200
CB-1	200	400	#16mm	4	2	4	2	4	2	1#50, 6#100, REST#200	
TIE BEAM											
	TG-1	300	500	#20mm	5	4	2	2	6	4	1#50, 8#100, REST#200
	TG-2	300	500	#20mm	6	4	2	3	6	4	1#50, 8#100, REST#200
	TG-3	300	500	#20mm	3	3	2	2	3	3	1#50, 6#100, REST#200
STAIR BEAM											
	STB-1	200	400	#16mm	3	2	2	4	3	2	1#50, 6#100, REST#200




B
S-3 STAIR FRAMING PLAN (TYP)
SCALE 1:50 M




C
S-3 STAIR SECTION DETAIL
SCALE 1:50 M




D
S-3 SECTION OF STAIR SLAB
SCALE 1:25 M




DC-1
(FROM LANDING TO 2ND/3RD FLOOR LEVEL)



E
S-3 SPOT DETAIL
SCALE 1:25 M




F
S-3 SPOT DETAIL
SCALE 1:25 M




G
S-3 SPOT DETAIL
SCALE 1:25 M

<p>REPUBLIC OF THE PHILIPPINES DEPARTMENT OF EDUCATION (DepED) TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING MERALCO AVENUE, PASIG CITY</p>	CONSULTANT / DESIGNER	REVIEWED BY:	RECOMMENDING APPROVAL :	APPROVED FOR ACCREDITATION :	CONCURRED :	PROJECT TITLE :	PROJECT NO: 01-002	OWNER :	SHEET NO:
	 BERNADETTE N. AQUINO ENGINEER III	 WILFREDO S. LOPEZ OIC, STRUCTURAL DIVISION BUREAU OF DESIGN, DPWH	 SOFIA T. SANTIAGO OIC, DIRECTOR III BUREAU OF DESIGN, DPWH	 GILBERTO S. REYES OIC, DIRECTOR IV BUREAU OF DESIGN, DPWH	 RAMON C. BACANI UNDERSECRETARY DEPARTMENT OF EDUCATION (DepED)	THREE STOREY SIX CLASSROOM W/MULTI-PURPOSE	DESIGNED BY: BNA ENCODED BY: BNA	DEPARTMENT OF EDUCATION DepED	S-3 4
	PRC NO. : 0074495 PTR NO. : TIN : 199-674-196 DATE :					LOCATION :	CHECKED BY:	SHEET CONTENTS :	
							DATE : 01 03	SCHEDULE OF BEAMS/GIRDERS DETAIL OF STAIR	


NOTE: THIS DRAWING, AS AN INSTRUMENT OF SERVICE IS THE PROPERTY OF TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING AND AS SUCH MUST NOT BE REPRODUCED OR COPIED IN PART OR IN WHOLE WITHOUT THEIR PERMISSION. ALL DRAWINGS ARE TO BE RETURNED WHEN NO LONGER IN USE.




SCHEDULE OF TRUSS MEMBERS			
MARK	DESCRIPTION	QTY	SIZE
W-1	COLUMN	2L	2.5"x2"x5/16" (SHORT LEGS BACK TO BACK)
W-2	TOP & BOTTOM CHORDS	2L	2"x2"x1/4"
W-3	WEB MEMBERS	L	2"x2"x1/4"




A
S-3 **DIAGRAM OF STRUT-I**
SCALE 1 : 25 M




B
S-4 **CONNECTION DETAIL**
SCALE 1 : 10 M




C
S-4 **CONNECTION DETAIL**
SCALE 1 : 10 M



D
S-4 **CONNECTION DETAIL**
SCALE 1 : 10 M




E
S-4 **CONNECTION DETAIL**
SCALE 1 : 10 M




F
S-4 **SAG ROD CONNECTION DETAIL**
SCALE 1 : 10 M


A
S-3 **DIAGRAM OF T-I**
SCALE 1 : 25 M



G
S-4 **PURLIN CONNECTION DETAIL**
SCALE 1 : 10 M




PLAN



SECTION

H
S-4 **CONNECTION DETAIL**
SCALE 1 : 10 M




I
S-4 **CONNECTION DETAIL**
SCALE 1 : 10 M


<p>REPUBLIC OF THE PHILIPPINES DEPARTMENT OF EDUCATION (DepED) TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING MERALCO AVENUE, PASIG CITY</p>	CONSULTANT / DESIGNER	REVIEWED BY:	RECOMMENDING APPROVAL :	APPROVED FOR ACCREDITATION :	CONCURRED :	PROJECT TITLE :	PROJECT NO: 01-002	OWNER :	SHEET NO:	
	 BERNADETTE N. AQUINO ENGINEER III PRC NO. : 0074495 TIN : 199-674-196 PTR NO. : _____ DATE : _____	 WILFREDO S. LOPEZ OIC, STRUCTURAL DIVISION BUREAU OF DESIGN, DPWH	 SOPIA T. SANTIAGO OIC, DIRECTOR III BUREAU OF DESIGN, DPWH	 GILBERTO S. REYES OIC, DIRECTOR IV BUREAU OF DESIGN, DPWH	 RAMON C. BACANI UNDERSECRETARY DEPARTMENT OF EDUCATION (DepED)	THREE STOREY SIX CLASSROOM W/MULTI-PURPOSE LOCATION :	DESIGNED BY: BNA ENCODED BY: BNA CHECKED BY: DATE : 01 03	DEPARTMENT OF EDUCATION DepED SHEET CONTENTS : TRUSS DIAGRAM DETAILS OF STEEL CONNECTION	S-4 4	

NOTE: THIS DRAWING, AS AN INSTRUMENT OF SERVICE IS THE PROPERTY OF TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING AND AS SUCH MUST NOT BE REPRODUCED OR COPIED IN PART OR IN WHOLE WITHOUT THEIR PERMISSION. ALL DRAWINGS ARE TO BE RETURNED WHEN NO LONGER IN USE.








REP. ACT 545



2 ROOF DRAIN LAYOUT
P-1 SCALE : 1 : 100 METERS




1 PLUMBING RO-IN LAYOUT
P-1 SCALE : 1 : 100 METERS

<div><div>REPUBLIC OF THE PHILIPPINES DEPARTMENT OF EDUCATION (DepED) TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING MERALCO AVENUE, PASIG CITY</div></div>	CONSULTANT / DESIGNER	REVIEWED BY:	RECOMMENDING APPROVAL :	APPROVED FOR ACCREDITATION :	CONCURRED :	PROJECT TITLE :	PROJECT NO: 01-002	OWNER :	SHEET NO:	
	<div> BERNADETTE N. AQUINO</div> <div>ENGINEER III PRC NO. : 0074495 TIN : 199-674-196 PTR NO. : DATE : </div>	<div> WILFREDO S. LOPEZ</div> <div>OIC, STRUCTURAL DIVISION BUREAU OF DESIGN, DPWH</div>	<div> SOFIA T. SANTIAGO</div> <div>OIC, DIRECTOR III BUREAU OF DESIGN, DPWH</div>	<div> GILBERTO S. REYES</div> <div>OIC, DIRECTOR IV BUREAU OF DESIGN, DPWH</div>	<div> RAMON C. BACANI</div> <div>UNDERSECRETARY DEPARTMENT OF EDUCATION (DepED)</div>	THREE STOREY SIX CLASSROOM W/MULTI-PURPOSE	DESIGNED BY: BNA ENCODED BY: BNA CHECKED BY: DATE : 01 03	DEPARTMENT OF EDUCATION DepED	SHEET CONTENTS : ROOF DRAIN LAYOUT , PLUMBING RO-IN LAYOUT	P-1 3

NOTE: THIS DRAWING, AS AN INSTRUMENT OF SERVICE IS THE PROPERTY OF TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING AND AS SUCH MUST NOT BE REPRODUCED OR COPIED IN PART OR IN WHOLE WITHOUT THEIR PERMISSION. ALL DRAWINGS ARE TO BE RETURNED WHEN NO LONGER IN USE.


REP. ACT 545



<div><div><div></div><div>REPUBLIC OF THE PHILIPPINES</div><div>DEPARTMENT OF EDUCATION (DepED)</div><div>TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING</div><div>MERALCO AVENUE, PASIG CITY</div></div><div><div></div><div></div></div></div>	CONSULTANT / DESIGNER	REVIEWED BY:	RECOMMENDING APPROVAL :	APPROVED FOR ACCREDITATION :	CONCURRED :	PROJECT TITLE :	PROJECT NO: 01-002	OWNER :	SHEET NO:
	<div><div><div><div><div></div><div>BERNADETTE N. AQUINO</div></div><div>ENGINEER III</div><div>PRC NO. : 0074495</div><div>TIN : 199-674-196</div><div>PTR NO. : </div><div>DATE : </div></div></div></div>	<div><div><div><div><div></div><div>WILFREDO S. LOPEZ</div></div><div>OIC, STRUCTURAL DIVISION</div><div>BUREAU OF DESIGN, DPWH</div></div></div></div>	<div><div><div><div><div></div><div>SOFIA T. SANTIAGO</div></div><div>OIC, DIRECTOR III</div><div>BUREAU OF DESIGN, DPWH</div></div></div></div>	<div><div><div><div><div></div><div>GILBERTO S. REYES</div></div><div>OIC, DIRECTOR IV</div><div>BUREAU OF DESIGN, DPWH</div></div></div></div>	<div><div><div><div><div></div><div>RAMON C. BACANI</div></div><div>UNDERSECRETARY</div><div>DEPARTMENT OF EDUCATION (DepED)</div></div></div></div>	THREE STOREY SIX CLASSROOM W/MULTI-PURPOSE	DESIGNED BY: BNA	DEPARTMENT OF EDUCATION DepED	P-2
						LOCATION :	ENCODED BY: BNA	SHEET CONTENTS :	3
							CHECKED BY:	ISOMETRIC VIEW	
							DATE : 01 03		

NOTE: THIS DRAWING, AS AN INSTRUMENT OF SERVICE IS THE PROPERTY OF TASK FORCE ENGINEERING, ASSESSMENT AND MONITORING AND AS SUCH MUST NOT BE REPRODUCED OR COPIED IN PART OR IN WHOLE WITHOUT THEIR PERMISSION. ALL DRAWINGS ARE TO BE RETURNED WHEN NO LONGER IN USE.

REP. ACT 545



- PLUMBING NOTES:

1. GRADES OF HORIZONTAL PIPINGS
RUN ALL HORIZONTAL PIPINGS IN PERFECT ALIGNMENT AND AT A FORM GRADE NOT LESS THAN TWO PERCENT (2%)
2. CHANGE IN DIRECTION
ALL CHANGE IN DIRECTION SHALL BE MADE BY APPROPRIATE USE OF FORTY-FIVE DEGREES (45') WYES, LONG SWEEP QUARTER BEND, SIXTH-EIGHT OR SIXTEENTH BEND. WHEN THE CHANGE OF FLOW IS FROM HORIZONTAL TO VERTICAL A SINGLE 1/8 BEND COMBINATION MAYBE USED ON VERTICAL STACKS AND SHORT QUARTER BENDS MAYBE USED ON WASTE LINE, TEE AND CROSSES MAYBE USED IN BENT PIPES.
3. PROHIBITED FITTINGS
NO DOUBLE HUB OR TEE BRANCH SHALL BE USED ON HORIZONTAL SOIL AND WASTE LINES, THE DRILLINGS AND TAPPING OF HOUSE DRAIN, WASTE OR VENT PIPES AND USED OF SADDLE HUB AND BEND ARE PROHIBITED.
4. PIPE CLEAN-OUTS
CLEAN-OUTS ARE REQUIRED UNDER THE FOLLOWING CONDITIONS:
 - a) EVERY CHANGE OF HORIZONTAL DIRECTION EXCEEDING TWENTY TWO AND ONE-HALF DEGREES (22 1/2').
 - b) ONE AND ONE-HALF METERS (1.50m.) INSIDE THE PROPERTY LINES BEFORE THE HOUSE DRAINAGE CONNECTION.
 - c) EVERY FIFTEEN METERS (15.00m) IN HORIZONTAL RUN OF PIPES.
 - d) AT THE END OF ANY HORIZONTAL PIPE LINES.
5. THE DIGESTION CHAMBER OF SEPTIC VAULT MUST BE WATERPROOFED.
6. NOT LESS THAN 0.30 METER OF AIR SPACE MUST BE LEFT BETWEEN THE TOP OF THE SEWAGE AND THE UNDER PART OF VAULT ROOF SLAB.
7. NO SEPTIC VAULT SHALL BE CONSTRUCTED UNDER THE BUILDING.
8. ALL PLUMBING WORK SHALL BE UNDER THE SUPRVISION OF A LICENSED MASTER PLUMBER AND A LICENCED PLUMBING CONTRACTOR.

DESIGN CRITERIA

- i. LIVE LOAD _____ 1000Pa
- ii ALLOWABLE STRESSES
 1. CONCRETE
 - a. FOR FOOTING, BEAMS AND SLABS
$$f_c' = 20 \text{ MPa}$$
 2. CONCRETE MASONRY UNITS (LOAD BEARING CHB)
$$f_m' = 6.90 \text{ MPa}, f_m = 2.41 \text{ MPa}$$
 3. REINFORCING STEEL BARS
FOR BARS SMALLER THAN 16mm
$$f_y = 230 \text{ MPa}$$
 4. ASSUMED ALLOWABLE BEARING CAPACITY $\gamma = 100 \text{ KPa}$

NOTE:

- WATER TABLE IS 1500 BELOW GROUND LEVEL