



Page 1 of 1



**Standard Technical Specifications for
Uninterruptible Power Supply**

Name of Equipment: UPS (3000va) for Network Room / Building Distributor

Description: Continuous power supply and data loss prevention.

Main Equipment Components	Specification
<i>Power Ratings</i>	3000VA/2700W
	230V - Input/Output Voltage
	13 minutes back-up power at half load (internal batteries only)
	3 hours recharge time (internal batteries only)
<i>IO Ports</i>	USB, RJ45 / SNMP Card
<i>Outlets</i>	6 power output/connectors
<i>Features</i>	Built-in Automatic Voltage Regulator (AVR), Automatic self-test (built-in), Alarms (Online, on battery, replacement battery, and overload)
Software	
<i>Management Software</i>	Built-in or with media installer monitoring tool and diagnostic software accessible via desktop application and/or web browser.
Accessories	Specification
<i>Cables and Connectors</i>	All necessary cables and connectors
<i>Other Inclusion</i>	Mounting Kit, 1 Extended Battery Module

Other Requirements:

Brand and Model: Must be an International Brand Name with an existence of at least five (5) years in the Philippines. The unit model must be in the current catalog and not end-of-life. Manufacturer's certificate is required.

Documentation and Media: The equipment shall be supplied with the standard manufacturer documentation, on any electronic storage media and hard copy version where available.

Warranty and Maintenance: The Supplier must provide a three (3) year warranty for parts and on-site labor from the date of the Inspection and Acceptance Report.

Technical Support: The local technical support shall include telephone and email, 8 hours per day (8:00 am - 5:00 pm) 5 days a week (Monday - Friday) for problem resolution. Support shall have a response time of the next business day.

Prepared by:

Checked by:

MARY JANE N. PANTOJA
Chief, Business Innovation Division

RHALF B. CAWALING
Director, Information Management Service

Approved by:

ADOR G. CANLAS, CESO IV
Undersecretary, Technical Services
and Information Management Service

Approved Date: **081624**