

Lot 2	Supply and Installation of Floor Mounted Airconditioner (ROWALD Conference Room)	1	unit		P
	Specifications:				
	IDU Dimension: 610x390x1,925 mm (WDH)				
	ODU Dimension: 952x415x1333 mm (WDH)				
	Capacity: 5.0				
	Cooling Capacity: BTU 55,000				
	kJ/h 58,025				
	Power Supply: 230/60/3 (V/Hz/ph)				
	Rated Power (W): 5,650				
	Rated Current (A): 16.0				
	EER: 10.30 (kJ/Hr-W)				
	Refrigerant: R410A				
	Quiet function				
	Inverter model				
	Inclusions:				
	1. 18 meters of wire from panel board to condenser/outdoor/Conduit/ Electric Pipes				
	2. Panel Board 3 Phase Bolt on 5 Branches				
	3. Main Breaker MCB 100 Amperes with Main Wire THHN				
	4. 40 Amperes Circuit Breaker				
	5. 1 enclose, NEMA with Circuit Breaker, 3Phase, 40 Amperes				
	6. 10 meters pipe line between indoor and outdoor aircon				
	ABC Lot 2 = Php 281,772.33				
	-&&&&&&&&&&&&&&&&&&&&&&-				
	TOTAL AMOUNT				P
	Please write total amount in words				
	Please specify brand name, if applicable.				

Brand and Model: _____
Delivery Period: _____

After having carefully read and accepted your General Conditions, I / We quote you in the item(s) at prices note above. If the space for Delivery Period, Warranty and Price Validity are left blank, it means that I concur with the Terms and Conditions specified by DPWH.

Printed Name/Signature/Date