

June 25, 2020

MEMORANDUM

FOR : **MARK A. VILLAR**
Secretary
This Department

This refers to the memorandum dated June 3, 2020 of **DPWH Region XI Director ALLAN S. BORROMEIO**, endorsing the request of **District Engineer RICHARD A. RAGASA, Davao City District Engineering Office**, for the **modification** of the project under FY 2020 GAA, to wit;

| As per GAA/Original | | | As Modified | | |
|--|---------------------|--------------|---|---------------------|----------------|
| Project Description | | | | | |
| UACS No. 300106200521000 Project ID:P00444637MN | | | | | |
| Local Program – Flood Control Structures / Facilities - Construction / Repair / Rehabilitation / Improvement of Various Infrastructure including Local Projects | | | Local Program – Flood Control Structures / Facilities - Construction / Repair / Rehabilitation / Improvement of Various Infrastructure including Local Projects | | |
| Construction of Flood Mitigation Structure along Matina River, Matina River Outfall Section, Both Bank, Davao City | | | Construction of Flood Mitigation Structure along Matina River, Matina River Outfall Section, Both Bank, Davao City | | |
| Type of Work/ Physical Target | Unit Cost | Allocation | Type of Work/ Physical Target | Unit Cost | Estimated Cost |
| CW1- Construction of Flood Mitigation Structure/ 90.000 lm | P 315,777.78/ lm | P 28,420,000 | Construction of Flood Mitigation Structure/ 130.000 lm | P 218,615.38/ lm | P 28,420,000 |
| EAO | - | P 580,000 | EAO | - | P 580,000 |
| Total: | | P 29,000,000 | Total: | | P 29,000,000 |
| Justification: | | | | | |
| <ul style="list-style-type: none">Increase in physical target from 90 lineal meters to 130 lineal meters due to minimal earthworks since height of embankment is only 3meters instead of the anticipated 6 meters. | | | | | |

Based on our evaluation, the submitted request for modification of the said project is in order; hence, approval hereof is recommended.


DIMAS S. SOGUILON, CESO I
Undersecretary for Regional Operations in Mindanao

APPROVED/DISAPPROVED:

MARK A. VILLAR
Secretary

2.3 mksa/LCA/AVS/DSS

Department of Public Works and Highways
Office of the Secretary



WINDG03162

*See RD Memo dtd 9/7/20 + DE Memo dtd 9/3/20 re Reasonableness of Cost
w/c is relatively very high*