



10 APR 2018

Republic of the Philippines  
DEPARTMENT OF PUBLIC WORKS AND HIGHWAYS  
**OFFICE OF THE SECRETARY**  
Manila

**MEMORANDUM**

**FOR :** **MARK A. VILLAR**  
Secretary  
This Department

This refers to the memorandum dated **23 March 2018** of **DPWH Region VII Director ADOR G. CANLAS, CESO IV**, requesting for the approval of the **Modification** of the project under FY 2018 General Appropriation Act (GAA), to wit;

| As per GAA/Original   |                       |                        | As Modified  |                       |                            |
|---|-----------------------|------------------------|--|-----------------------|----------------------------|
| Project Description   |                       |                        |  |                       |                            |
| UACS No. 320101101894000<br>Project ID: P00223428VS   |                       |                        |  |                       |                            |
| 002:Protect Lives and Properties-Flood Management Program-Construction /Maintenance of Flood Control Mitigation Structure and Drainage System.                          |                       |                        | 002:Protect Lives and Properties-Flood Management Program-Construction /Maintenance of Flood Control Mitigation Structure and Drainage System. |                       |                            |
| Construction of Revetments (Gabions) along Suba River at Suba Bridge-Downstream, (K0050+640) Sibonga,Cebu   |                       |                        | Construction of Revetments (Gabions) along Suba River at Suba Bridge, (K0050+640) Sibonga,Cebu   |                       |                            |
| Physical Target   | Unit Cost<br>P ('000) | Allocation<br>P ('000) | Physical Target  | Unit Cost<br>P ('000) | Estimated Cost<br>P ('000) |
| CW1- Construction of Flood Mitigation Structure<br>450 lm   | P 54.44/lm            | P 24,500               | CW1- Construction of Revetment<br>376 lm.  | P 65.16 lm            | P 24,500                   |
| EAO   |                       | 500                    | EAO  |                       | 500                        |
| Total:  |                       | P 25,000               | Total:   |                       | P 25,000                   |
| Justification:  |                       |                        |  |                       |                            |
| 1. Typographical Error. There is already an existing structure and does not need to be improved (As certified by the District Engineer)                                 |                       |                        |  |                       |                            |
| 2. The decrease in physical target from 450 lm to 376 lm due to the installation of 6 layers and 7 layers gabions instead of 5 layers to avoid settlement of river bed. |                       |                        |  |                       |                            |

Based on our evaluation, the submitted request for modification of the said project is found in order. Hence, the said request is hereby recommended for the Secretary's consideration and approval.

**ROBERTO R. BERNARDO**  
Undersecretary for Operations  
In Visayas, NCR, and Region IV-B

**APPROVED/DISAPPROVED:**

**MARK A. VILLAR**  
Secretary

3.4 APJ/RRB

**ROBERTO R. BERNARDO**  
Undersecretary  
OFFICER - IN - CHARGE

Department of Public Works and Highways  
Office of the Secretary



WIN8F05416