



25 MAY 2018

Republic of the Philippines
DEPARTMENT OF PUBLIC WORKS AND HIGHWAYS
 OFFICE OF THE SECRETARY
 Bonifacio Drive, Port Area, Manila

MEMORANDUM

FOR : Secretary MARK A. VILLAR
 This Department


This refers to the Memorandum dated 4 May 2018 of **DPWH NCR Regional Director MELVIN B. NAVARRO**, endorsing the request for approval of **Modification** of District Engineer Ramon P. Devanadera, Quezon City 2nd District Engineering Office of the project under FY 2018 General Appropriation Act (GAA), to wit;

As per GAA/Original			As Modified		
Project Description					
UACS No. 310112100012000 Project ID: P00200707LZ					
001: Ensure Safe and Reliable National Road System			001: Ensure Safe and Reliable National Road System		
Asset Preservation - Construction/ Upgrading/ Rehabilitation of Drainage along National Roads - Tertiary Roads			Asset Preservation - Construction/ Upgrading/ Rehabilitation of Drainage along National Roads - Tertiary Roads		
Camp Crame Rd Network – (S05562LZ) Chainage 0 – Chainage 131, (S05563LZ) Chainage 0- Chainage 127, (S05564LZ) Chainage 0- Chainage 170, (S05566LZ) Chainage 0- Chainage 325			Camp Crame Rd Network – (S05562LZ) Chainage 0 – Chainage 131, (S05563LZ) Chainage 0- Chainage 127, (S05564LZ) Chainage 0- Chainage 393, (S05566LZ) Chainage 0- Chainage 325		
Physical Target CW1 - Upgrading of Drainage Structure along Road L = 1,506 lineal meter	Unit Cost(P'000) P14.97/lineal meter	Allocation ('000) P22,540.00	Physical Target CW1 - Upgrading of Drainage Structure along Road L = 1,125 lineal meter	Unit Cost(P'000) P20.04/lineal meter	Allocation ('000) P22,540.00
EAO	-	P 460.00	EAO	-	P 460.00
Total :		P 23,000.00	Total :		P 23,000.00
Justifications:					
<ul style="list-style-type: none">Change in station limit from (S05564LZ) Chainage 0 - Chainage 170 to (S05564LZ) Chainage 0 - Chainage 393 since the whole stretch of road section (S05564LZ) Chainage 0 – Chainage 393 with a total length of 393.00 meters has no existing drainage structure.Decreased in physical target from 1,506.00 lineal meters to 1,125.00 lineal meters due to the required size of RCCP from 30” diameter to 36” diameter and provision of Reinforced Concrete Manhole.					


Camp Crame Rd Network – (S05562LZ) Chainage 0 –
Chainage 131, (S05563LZ) Chainage 0- Chainage 127,
(S05564LZ) Chainage 0- Chainage 393, (S05566LZ)
Chainage 0- Chainage 325

Page 2/2

Based on our evaluation, the submitted request for modification of the said project is found in order.
Hence, the said request is hereby recommended for the Secretary's consideration and approval.


ROBERTO R. BERNARDO
Undersecretary for Operations
in Visayas, NCR and Region IV-B

APPROVED/DISAPPROVED:


MARK A. VILLAR
Secretary

Department of Public Works and Highways
Office of the Secretary



WIN8F05535