



May 07, 2021

MEMORANDUM

FOR : MARK A. VILLAR
Secretary
This Department

This refers to the Memorandum dated 27 April 2021 of DPWH Region XI OIC-Regional Director REY PETER B. GILLE, DM, endorsing the request of District Engineer Richard A. Ragasa, Davao City District Engineering Office for the modification of the project under FY 2021 GAA, to wit:

As per GAA/Original			As Modified		
Project Description					
UACS No. 300117210295000 Project ID: P00551304MN					
Local Program – Local – Local Roads and Bridges – Local Roads – Local Infrastructure Program			Local Program – Local – Local Roads and Bridges – Local Roads – Local Infrastructure Program		
Road Widening, Barangay 26-C, Poblacion, Davao City			Road Widening, Barangay 26-C, Poblacion, Davao City		
Type of Work/ Physical Target	Unit Cost	Allocation	Type of Work/ Physical Target	Unit Cost	Estimated Cost
CW1- Road Widening / 0.805 Lane Km	P 4,304,347.83 /Lane Km	P 3,465,000.00	CW1- Road Widening / 0.300 Lane Km	P 11,550,000.00 /Lane Km	P 3,465,000.00
EAO	-	P 35,000.00	EAO	P 23 m/m	* P 35,000.00
Total:		P3,500,000.00	Total:		P3,500,000.00
Justification: 67% decrease in target Decrease in physical target from 0.805 lane km to 0.300 lane km due to the following:					
<ul style="list-style-type: none">• The project design considers 2-meter width of road widening for 150 lineal meters on both sides to maximize and increase the carriageway width from 6.7 meters to 10.7 meters, in order to minimize traffic congestion;• The Portland Cement Concrete Pavement (PCCP) used in the design was of 7-day concrete instead of the usual 14-day and 28-day concrete since road section is located within in a highly urbanized area, hence, higher unit cost;• Project includes construction of 142 lineal meters of drainage structure using 910mm dia RCPC (Class IV) including manhole with iron ductile cover (for road safety purposes) and also to alleviate flooding in the area; and• Scope of work also includes removal of actual structures/obstructions (existing concrete) and reconditioning of drainage structures.					

Based on our evaluation, the submitted request for modification of the said project is in order; hence, approval hereof is recommended.

EUGENIO R. PIPO, JR.
Undersecretary for Regional Operations in Mindanao

APPROVED/DISAPPROVED:

MARK A. VILLAR
Secretary

2.3 JFF/LCA/AVS/ERP

Department of Public Works and Highways
Office of the Secretary



WIN1E02526