



Republic of the Philippines  
DEPARTMENT OF PUBLIC WORKS AND HIGHWAYS  
**OFFICE OF THE SECRETARY**

Reference Number: XII-082  
Project ID: P00833593MN



June 25, 2024

**MEMORANDUM**

**FOR :** **EUGENIO R. PIPO, JR.**  
Undersecretary for Regional Operations  
in CAR, Regions I, II, IX, X, XI, XII, and XIII


This refers to the memorandum dated 07 June 2024 of **DPWH Region XII Assistant Regional Director ROSIE C. JAVATE**, endorsing the request of **District Engineer EMEDIO C. ONTAL, MPA, Cotabato 1<sup>st</sup> District Engineering Office**, for the **modification** of the project under FY 2024 GAA, to wit;

As per GAA/Original			As Modified		
Project Description					
<b>UACS No. 300225102242000.</b> <b>Project ID: P00833593MN.</b>  Convergence and Special Support Program: Basic Infrastructure Program (BIP) - Flood Mitigation Structures protecting Public Infrastructures/Facilities .  Construction of Drainage Canal along Kitao Creek, Central Katingawan, Midsayap, Cotabato .			Convergence and Special Support Program: Basic Infrastructure Program (BIP) - Flood Mitigation Structures protecting Public Infrastructures/Facilities .  Construction of Drainage Canal along Kitao Creek, Central Katingawan, Midsayap, Cotabato .		
Type of Work/ Physical Target	Unit Cost	Allocation	Type of Work/ Physical Target	Unit Cost	Estimated Cost
CW-1- Construction of Drainage Structure:  36.047 lineal meters	₱ 137,320.72/ lineal meter	₱ 4,950,000.00	CW-1-Construction of Drainage Structure:  940.00 lineal meters	₱ 5,265.96/ lineal meter	₱ 4,950,000.00
EAO	—	₱ 50,000.00	EAO	—	₱ 50,000.00
Total:		₱ 5,000,000.00	Total:		₱ 5,000,000.00
Justification: <ul style="list-style-type: none"><li>• The increase in the physical target/decrease in unit cost is based on the validated and approved Program of Works (POW) and Detailed Unit Price Analysis (DUPA).</li><li>• The project is composed of 186.00 meters of reinforced concrete covered drainage canal with catch basins and 754.00 meters earth canal.</li><li>• The concrete canal has a height of 1.15m, opening width of 0.70m wall thickness 0.20m and reinforced with 12mm diameter RSB. The concrete cover has a thickness of 0.22m and reinforced with 16 mm diameter RSB.</li><li>• Excavation of the existing earth canal was deemed necessary to attain the needed elevation to drain the water to the existing creek.</li></ul>					

41-10-202406-62521




Based on our evaluation, the submitted request for modification of the said project is in order; hence, approval hereof is recommended.

  
**REY PETER B. GILLE, D.M.**  
Assistant Secretary for Regional Operations  
in CAR, Regions I, II, IX, X, XI, XII, and XIII

**RECOMMENDING APPROVAL:**

  
**MARIA CATALINA E. CABRAL, Ph.D., CESO I**  
Undersecretary for Planning  
and Public-Private Partnership Services

**APPROVED/~~DISAPPROVED~~:**

  
**EUGENIO R. PIRO, JR.**  
Undersecretary for Regional Operations  
in CAR, Regions I, II, IX, X, XI, XII, and XIII

2.3 mksa/AVS/RPBG/ERP